

**TABLE 1**

**Drinking Water Sampling for Lead Content  
Roxana Community Unit School District #1  
South Primary School  
Sampled: September 14, 2017**

<b>Sample ID</b>	<b>Location</b>	<b>Water Source</b>	<b>Results (ppb)</b>
01	Kitchen- Hand Wash Station	Sink	<1.0
01A	Kitchen- Hand Wash Station	Sink	<1.0
02	Kitchen- Single Bay	Sink	<1.0
02A	Kitchen- Single Bay	Sink	<1.0
03	Kitchen- 3 Bay -Left	Sink	Non- Functional
03A	Kitchen- 3 Bay -Left	Sink	Non- Functional
04	Kitchen- 3 Bay -Right	Sink	6.5
04A	Kitchen -3 Bay -Right	Sink	<1.0
05	Kitchen- Dishwasher Sprayer	Sprayer	Non- Functional
05A	Kitchen-Dishwasher Sprayer	Sprayer	Non- Functional
06	Kitchen -Pot Filler	Sprayer	2.8
06A	Kitchen- Pot Filler	Sprayer	1.1
07	Outside Room 069 (Non-Functional)	Fountain	Non- Functional
07A	Outside Room 069 (Non-Functional)	Fountain	Non- Functional
08	Outside Room 071	Fountain	<1.0
08A	Outside Room 071	Fountain	<1.0
09	Nurse Office 062 Bathroom sink	Sink	1.8
09A	Nurse Office 062 Bathroom sink	Sink	<1.0
10	Cafeteria- Left	Fountain	<1.0
10A	Cafeteria- Left	Fountain	<1.0
11	Cafeteria- Right	Fountain	<1.0
11A	Cafeteria-Right	Fountain	<1.0
12	Outside of Library 055	Fountain	<1.0
12A	Outside of Library 055	Fountain	<1.0
13	Outside of Room 040	Fountain	<1.0
13A	Outside of Room 040	Fountain	<1.0
14	Outside of Room 035	Fountain	<1.0
14A	Outside of Room 035	Fountain	<1.0
15	Outside of Room 022	Fountain	<1.0
15A	Outside of Room 022	Fountain	1.0
16	Room 025	Sink	1.3
16A	Room 025	Sink	<1.0
17	Room 025	Fountain	<1.0
17A	Room 025	Fountain	<1.0
18	Room 022	Sink	7.0
18A	Room 022	Sink	1.6
19	Room 022	Fountain	3.8
19A	Room 022	Fountain	1.9
20	Room 023	Sink	9.3
20A	Room 023	Sink	1.6

Sample ID	Location	Water Source	Results (ppb)
21	Room 023	Fountain	<1.0
21A	Room 023	Fountain	<1.0
22	Room 018	Sink	4.6
22A	Room 018	Sink	<1.0
23	Room 018	Fountain	3.6
23A	Room 018	Fountain	<1.0
24	Room 019	Sink	2.0
24A	Room 019	Sink	<1.0
25	Room 019	Fountain	1.1
25A	Room 019	Fountain	<1.0
26	Room 016	Sink	5.2
26A	Room 016	Sink	<1.0
27	Room 016	Fountain	3.8
27A	Room 016	Fountain	<1.0
28	Room 017	Sink	3.2
28A	Room 017	Sink	<1.0
29	Room 017	Fountain	6.4
29A	Room 017	Fountain	<1.0
30	Room 014	Sink	<1.0
30A	Room 014	Sink	<1.0
31	Room 015	Sink	<1.0
31A	Room 015	Sink	<1.0
32	Building Services 013	Fountain	<1.0
32A	Building Services 013	Fountain	<1.0
33	Room 004- Left	Sink	1.2
33A	Room 004- Left	Sink	<1.0
34	Room 004-Right	Sink	<1.0
34A	Room 004-Right	Sink	<1.0
35	Room 003-Left	Sink	<1.0
35A	Room 003-Left	Sink	<1.0
36	Room 003-Right	Sink	<1.0
36A	Room 003-Right	Sink	<1.0
37	Outside of Room 003	Fountain	<1.0
37A	Outside of Room 003	Fountain	<1.0
38	Outside of Room 001	Fountain	<1.0
38A	Outside of Room 001	Fountain	<1.0
39	Room 002- Left	Sink	<1.0
39A	Room 002-Left	Sink	<1.0
40	Room 002-Right	Sink	<1.0
40A	Room 002-Right	Sink	<1.0
41	Room 001- Left	Sink	<1.0
41A	Room 001- Left	Sink	<1.0
42	Room 001-Right	Sink	<1.0
42A	Room 001-Right	Sink	<1.0

A/B Samples were precautionary samples collected at 30 seconds following the “first draw” samples (A) and 3 minutes following the A sample (B).

#####

Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.

#####

Water source is < 20 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum